

PRODUCT SAFETY DATA INFORMATION

Date: 12 August 2021

Data Sheet Number: PSDI ELD96_Family Revision: 1

SECTION 1 – Product Identification

This 'Product Safety Data Information' Sheet covers Pall Medical ELD96 product variants

Product name(s): PALL Nanodyne™ ELD Filter and PALL Posidyne® ELD Filter

Part Number(s): See appendix 1

The filters detailed above are air-eliminating filters for professional use only and designed for 96-hour particle, bacteria, and endotoxin retention

For further information on Pall products, please visit Pall at <https://www.pall.com/en/about-pall.html>

SECTION 2 - Hazards Identification

Product definition: Article.

These products are not classified as hazardous according to REACH Regulation 1907/2006, or European CLP/GHS Regulation 1272/2008.

GHS Signal word: No signal word.

Hazard statements: No known significant effects or critical hazards.

Special packaging requirements: None.

SECTION 3 - Materials of Construction

3.1 The filters detailed in Section 1 are comprised of the following materials:

Filter assembly (All codes)

Material Name	CAS Number
Modified acrylic copolymer housings	Supplier proprietary information
Polyamide main membrane	Pall proprietary information
Black Ink	Pall proprietary information
Polytetrafluoroethylene (PTFE) vent membrane	9002-84-0
Polyester vent membrane non-woven support	25038-59-9

Pall Corporation provides the information contained herein in good faith and states that it represents the best information currently available. However no warranties or representations are expressed or implied and Pall Corporation assumes no liabilities resulting from its use. Users should make their own investigations to determine the suitability of the information for their applications. In no way shall Pall Corporation be responsible for losses or damages resulting from the use or reliance on this information.

PRODUCT SAFETY DATA INFORMATION

Date: 12 August 2021

Data Sheet Number: PSDI ELD96_Family Revision: 1

Set components

Material Name	Product codes	CAS Number
DEHP free PVC tubing	ELD96LLCE, ELD96LYLE, ELD96LL, ELD96LYL, ELD96LYLS, ELD96NYS, ELD96NY, ELD96LLCJ, 100-0105	9002-86-2
MABS male luer connector	ELD96LLCE, ELD96LYLE, 100-0105, ELD96LYLS, ELD96NYS	9010-94-0
Acrylic male luer connector	ELD96LL, ELD96LYL, ELD96LLCJ, ELD96NY	Trade secret
Orange polyethylene hexene copolymer cap on male luer	ELD96LLCE, ELD96LYLE, 100-0105	25213-02-9
Polyethylene cap on male luer	ELD96NT, ELD96NTE	9002-88-4
Polyethylene dual protective cap	ELD96LL, ELD96LYL, ELD96LYLS, ELD96LLCJ, ELD96NY, ELD96NYS	9002-88-4
Polyethylene hexene copolymer slide clamp	ELD96LLCE, ELD96LYLE, ELD96LYL, ELD96NY, 100-0105	25213-02-9
Polyethylene slide clamp	ELD96LYLS, ELD96NYS	9002-88-4
Polypropylene slide clamp	ELD96LLCJ	9003-07-0
Acrylonitrile-butadiene-styrene copolymer (ABS) cap on female luer	ELD96LLCE, ELD96LYLE, 100-0105, ELD96NT, ELD96NTE	9003-56-9
Y connector – injection septum	ELD96LYLE, ELD96LYL, ELD96LYLS	Acrylic – Supplier proprietary information Synthetic Polyisoprene 9003-31-0
Y connector – needle-free access	ELD96NY, ELD96NYS	Acrylic – Supplier proprietary information, Silicone Rubber – Supplier proprietary information Polyurethane 9009-54-5
Polypropylene Rotating hub	ELD96NT, ELD96NTE	9003-07-0

These products are not known to contain BADGE, NOGE, or BFDGE.

Trace additives will be present in the plastic components.

There are no additional ingredients present which, within the current knowledge of the supplier, are classified and contribute to the classification of the article.

Pall Corporation provides the information contained herein in good faith and states that it represents the best information currently available. However no warranties or representations are expressed or implied and Pall Corporation assumes no liabilities resulting from its use. Users should make their own investigations to determine the suitability of the information for their applications. In no way shall Pall Corporation be responsible for losses or damages resulting from the use or reliance on this information.

PRODUCT SAFETY DATA INFORMATION

Date: 12 August 2021

Data Sheet Number: PSDI ELD96_Family Revision: 1

There are no current SVHC substances known to be present in the finished articles above 0.1%.

There are no current ROHS2 Directive (2011/65/EU) and amendment (2015/863) substances of concern (including Lead, Cadmium, Mercury, Hexavalent Chromium, Polybrominated biphenyl (PBB), Polybrominated diphenyl ether (PBDE), Bis(2-ethylhexyl) phthalate (DEHP), Benzyl Butyl Phthalate (BBP), Dibutyl phthalate (DBP) and Di-isobutyl phthalate (DIBP)) known to be present in the materials employed in excess of the limits laid down, based on information from our suppliers and knowledge of substances used within Pall the manufacturing facility.

Pall Medical filters do not employ natural rubber latex, or latex derivatives in their construction.

Pall Medical products do not knowingly contain materials of direct animal origin i.e. animal parts, tissues, or body fluids however, to assist our customers in performing a TSE/BSE risk assessment, we are pleased to provide the following information:

Certain plastics are known to contain trace levels of additive (e.g. calcium stearate) which are manufactured from tallow. Pall Medical products may utilize components in the fluid pathway which are fabricated from plastic resins containing tallow-derived additives at trace levels, but Pall does not test for them.

Please be advised that bovine tallow-derived additives are not considered specified TSE/BSE risk materials according to the current revision of the U.S. **Code of Federal Regulations**, Title 21 of part 189.5, which defines specified risk material for human food and Regulation (EU) 722/2012 concerning medical devices manufactured using tissues of animal origin, in Article 4, specifically excludes tallow derivatives provided they have been processed under conditions at least as rigorous as those stated in Section 3 of Annex 1 as shown below:

- Trans-esterification or hydrolysis at not less than 200 °C for not less than 20 minutes under pressure (glycerol, fatty acids and fatty acid esters production),
- Saponification with NaOH 12 M (glycerol and soap production)
- Batch process: at not less than 95 °C for not less than 3 hours,
- Continuous process: at not less than 140 °C, under pressure for not less than 8 minutes or equivalent,
- Distillation at 200 °C.

The plastics raw materials we purchase have been processed with one of these steps. Pall continuously works to assure the safety of our products with respect to potential BSE/TSE transmission by working through our supply chain to obtain information regarding the possible use of animal-based material and to confirm specific sourcing and processing details where applicable

SECTION 4 - First Aid Measures

4.1 First aid measures

Pall Corporation provides the information contained herein in good faith and states that it represents the best information currently available. However no warranties or representations are expressed or implied and Pall Corporation assumes no liabilities resulting from its use. Users should make their own investigations to determine the suitability of the information for their applications. In no way shall Pall Corporation be responsible for losses or damages resulting from the use or reliance on this information.

PRODUCT SAFETY DATA INFORMATION

Date: 12 August 2021

Data Sheet Number: PSDI ELD96_Family Revision: 1

Always address any contaminants present on the filter as the result of use.

Eye Contact:	Eye injury could result from physical impact. Get medical attention immediately.
Inhalation:	Inhalation is not considered a likely route of exposure for the filter product as supplied by Pall.
Skin Contact:	Wash with soap and water. If irritation persists, get medical attention.
Ingestion:	This material is not intended for ingestion and is not expected to present an ingestion hazard in the form and quantities present in a work-place setting. However, if ingestion occurs, seek medical attention.
Protection of first-aiders:	No action shall be taken involving any personal risk or without suitable training.

4.2 Key symptoms and effects

No known significant effects or critical hazards related to the materials of construction of the filter as supplied.

SECTION 5 - Fire Fighting Measures

5.1 Extinguishing media

Select an extinguish medium suitable for surrounding / working environment.

For filter set alone use dry chemical, CO₂, water spray (fog) or foam.

5.2 Specific Hazards

Warning: Combustion products of PTFE (fluoropolymers) can be released and be hazardous to humans and the environment.

Hazardous thermal decomposition products: CO, CO₂, acrid smoke, SO_x, Benzenesulfonic acid, 2(or 4) methyl- phenol, ketones, aldehydes, hydrogen chloride, benzene, unsaturated hydrocarbons, hydrogen cyanide, organic acids, formaldehyde, nitrogen oxides, isocyanates, isocyanic acid, amines, isoprene, di-pentene

Warning: thermal decomposition of PTFE can also produce fume particles and various toxic gases including hydrofluoric acid and carbonyl fluoride.

Polymer fume fever – chills, nausea, shortness of breath, chest tightness, muscle or joint ache – seek immediate medical attention.

Irritation to eyes. - suitable PPE and breathing apparatus precautions should be taken related to this risk in the event of fire.

5.3 Advice to Fire Fighters

Special precaution required. Fire-fighters should wear appropriate protective equipment, including self-contained breathing apparatus (SCBA) with a full face-piece operated in positive pressure mode.

Pall Corporation provides the information contained herein in good faith and states that it represents the best information currently available. However no warranties or representations are expressed or implied and Pall Corporation assumes no liabilities resulting from its use. Users should make their own investigations to determine the suitability of the information for their applications. In no way shall Pall Corporation be responsible for losses or damages resulting from the use or reliance on this information.

PRODUCT SAFETY DATA INFORMATION

Date: 12 August 2021

Data Sheet Number: PSDI ELD96_Family Revision: 1

Protective gloves must be worn when handling debris after a fire, due to PTFE thermal decomposition risks.

SECTION 6 - Accidental Release Measures

Warning: Do NOT incinerate without additional consideration of risk emissions and residues resulting from combustion of PTFE

6.1 Personal precautions, protective equipment and emergency procedures

No special measures are required in respect of the filters in the unused condition as supplied.

For used filters always address any contaminants present on the filter as the result of use.

6.2 Environmental precautions

For unused filter modules, place in designated waste container appropriate to the materials of construction listed in Section 3 and dispose of in accordance with local regulations via a licenced waste disposal contractor.

For used filter modules, using clear-up, containment and appropriate PPE measures related to the product being filtered and the materials of construction detailed in Section 3.

6.3 Spillage containment and cleaning up

Use suitable equipment to collect the filter material and place in a designated, labelled waste container.

Care should be taken to consider the nature of any contamination on the filter as the result of use and suitable PPE employed for handling medical waste.

Dispose of waste via a licensed waste disposal contractor.

SECTION 7 – Handling and Storage

7.1 Handling

Put on appropriate personal protective equipment for the working environment (See Section 8). Consult details of product being filtered for specific advice. Avoid activities that can damage the filter.

Follow good hygiene practices. Eating, drinking and smoking are generally prohibited in areas where this product is handled, stored or processed – exceptions are made on the guidance of local medical advice. Staff must follow standard work-place hygiene before eating, drinking or smoking after using this product. Wear gloves to prevent contamination of the filter cartridge and maintain cleanliness of the unused filter.

Pall Corporation provides the information contained herein in good faith and states that it represents the best information currently available. However no warranties or representations are expressed or implied and Pall Corporation assumes no liabilities resulting from its use. Users should make their own investigations to determine the suitability of the information for their applications. In no way shall Pall Corporation be responsible for losses or damages resulting from the use or reliance on this information.

PRODUCT SAFETY DATA INFORMATION

Date: 12 August 2021

Data Sheet Number: PSDI ELD96_Family Revision: 1

7.2 Storage

In the received condition, special protective equipment is not needed during handling and normal use of these filters. However, gloves are recommended to prevent contamination of the filter and maintain cleanliness. Handling of used filters must take into account the nature of potential contaminants.

The article is supplied dry, without the presence of any preserving fluid.
Store in clean, dry conditions suitable for a medical device.

Handle with care to avoid damage.

Do not expose to direct sunlight during storage, or other radiation or direct weather conditions.
Store in original shipping bag or boxing.
Ensure careful handling to avoid physical damage. Ensure shipping bag and seals are intact prior to use - do not use if damaged.

Please also consult Pall for further instructions for use information on the product prior to use.

SECTION 8 - Exposure Controls/Personal Protection**8.1 Control parameters**

Occupational Exposure limits: None required.

Recommended monitoring procedures: None required

8.2 Exposure controls

There are no special ventilation requirements for the article as supplied in the new and unused condition.

Hygiene Measures: No special measures required. Good hygiene practice in line with local working environmental requirements and medical guidelines.

Hand protection: Disposable gloves are recommended to ensure filter remains clean during installation.

Environmental Exposure Controls: Not normally required for the filter itself as supplied.

After the filter has been used additional exposure controls care should be taken in line with the nature of any contaminant on the filter as a result of its use.

SECTION 9 - Physical and Chemical Properties

Appearance: Disposable filter/filter set

Pall Corporation provides the information contained herein in good faith and states that it represents the best information currently available. However no warranties or representations are expressed or implied and Pall Corporation assumes no liabilities resulting from its use. Users should make their own investigations to determine the suitability of the information for their applications. In no way shall Pall Corporation be responsible for losses or damages resulting from the use or reliance on this information.

PRODUCT SAFETY DATA INFORMATION

Date: 12 August 2021

Data Sheet Number: PSDI ELD96_Family Revision: 1

Physical state:	Solid
Colour:	Various
Solubility:	All components Insoluble in water. Acrylic components readily soluble in esters, ketones and chlorinated hydrocarbons
Auto-ignition temperature:	Polypropylene >300 °C Acrylic: 440 °C (830 °F), decomposition begins at 250 °C (482 °F) PTFE; 520° - 560 °C, thermal decomposition >300 °C Polyester: 432 to 488 °C Polyamide: > 424 °C Ink: Not determined ABS: 416 °C Polyurethane: 416 °C Silicone rubber: Approximately 450 °C MABS: Not determined Polyethylene: 349 °C Polyethylene hexene copolymer: Not determined Synthetic polyisoprene: > 325 °C PVC: 435 to 557 °C
Sensitive to shock:	Mechanical / thermal shock can result in damage to the filter

SECTION 10 – Stability and Reactivity

Reactivity:	The filter is stable under the recommended conditions of use and storage.
Chemical Stability:	The filter is stable under recommended conditions of use and storage.
Hazardous Polymerisation:	Polymerisation will not occur under recommended conditions of use and storage.

Pall Corporation provides the information contained herein in good faith and states that it represents the best information currently available. However no warranties or representations are expressed or implied and Pall Corporation assumes no liabilities resulting from its use. Users should make their own investigations to determine the suitability of the information for their applications. In no way shall Pall Corporation be responsible for losses or damages resulting from the use or reliance on this information.

PRODUCT SAFETY DATA INFORMATION

Date: 12 August 2021

Data Sheet Number: PSDI ELD96_Family Revision: 1

Other hazardous reactions:	Consult details of product being filtered for specific advice. Under normal conditions of storage and use, no hazardous reactions will occur.
Conditions to Avoid:	Avoid hot surfaces or other conditions that soften, swell or adversely affect the filter or its materials of construction. Do not allow fluids to freeze on the filter
Incompatible Materials:	Strong Acids, alkalis and oxidising Agents (e.g. Perchloric Acid, nitric acid), alkali metals, strong alkalis and reducing agents, organic acids
Decomposition Products:	Under recommended conditions of use or storage, no hazardous decomposition products will be produced.

SECTION 11 - Toxicological Information

The information in this section contains generic advice and guidance in respect of the unused filter as supplied. Consult SDS details of the product being filtered for specific advice and recommendations.

11.1 Acute Toxicity

Based on typical information for the material type named, this information has not been determined specifically for Pall Medical filters

Mutagenicity / Carcinogenicity / Reproductive Toxicity / Teratogenicity: No known concern for the materials of construction of the filter as supplied (new and unused)

Aspiration Hazard: Not applicable for un-used filter.

Potential acute health effects: No known significant effects or critical hazards for the unused filter as supplied.

11.2 Chronic health effects

No known significant effects or critical hazards for the unused filter as supplied.

Carcinogenicity: No specific test data available, no evidence for hazardous properties

PRODUCT SAFETY DATA INFORMATION

Date: 12 August 2021

Data Sheet Number: PSDI ELD96_Family Revision: 1

SECTION 12 - Ecological Information

Pall Medical filters are not expected to degrade in contact with soil or water under ambient conditions.

SECTION 13 - Disposal Information

The information in this section contains generic advice and guidance.

Product

Methods of disposal:

Unused as supplied filters: Disposal/handling of the un-used filters should be in-line with national legislation and local regulatory requirements for the materials present. Unused filters may be used as land-fill.

Warning: Do NOT incinerate unused filters with general waste, as combustion products of PTFE (fluoropolymers) can be released and be hazardous to humans and the environment.

Hazardous Waste: To the best of our knowledge, this product if unused is not regarded as hazardous waste as defined by the EU Directive 91/689/EEC and amendments.

Used filters should be disposed of as clinical waste due to the nature of the contaminants on the filters as a result of use. Therefore, used filters may be classified as hazardous – clinical waste.

Packaging

Bagging: Plastic (polyethylene/polyester)

Box: Cardboard

The generation of waste should be avoided or minimised wherever possible. Waste packaging should be recycled where suitable arrangements and facilities exist. Incineration or landfill should only be considered where re-cycling is not feasible.

SECTION 14 - Transport Information

The clean and un-used filter, supplied in its original packaging, is not classified as dangerous goods under ADR, RID, IMDG or IATA regulations.

Pall Corporation provides the information contained herein in good faith and states that it represents the best information currently available. However no warranties or representations are expressed or implied and Pall Corporation assumes no liabilities resulting from its use. Users should make their own investigations to determine the suitability of the information for their applications. In no way shall Pall Corporation be responsible for losses or damages resulting from the use or reliance on this information.

PRODUCT SAFETY DATA INFORMATION

Date: 12 August 2021

Data Sheet Number: PSDI ELD96_Family Revision: 1

Notice to Reader

To the best of our knowledge, the information contained herein is accurate. However, neither the above Pall Corporation, nor any of its subsidiaries, assumes any liability whatsoever for the accuracy or completeness of the information contained herein.

Final determination of suitability of any materials is the sole responsibility of the user. All materials may present unknown hazards and should be used with caution. Although certain hazards are described herein, we cannot guarantee that these are the only hazards that exist.

“Pall” is a trademark of the Pall Corporation

® indicates a trademark registered in the USA

© Pall Corporation, 2021

Pall Corporation provides the information contained herein in good faith and states that it represents the best information currently available. However no warranties or representations are expressed or implied and Pall Corporation assumes no liabilities resulting from its use. Users should make their own investigations to determine the suitability of the information for their applications. In no way shall Pall Corporation be responsible for losses or damages resulting from the use or reliance on this information.

Page 10 of 11

PRODUCT SAFETY DATA INFORMATION

Date: 12 August 2021

Data Sheet Number: PSDI ELD96_Family Revision: 1

APPENDIX 1

ELD96LLCE	PALL Nanodyne™ ELD Filter - with female luer inlet, microbore tubing extension with clamp and male luer outlet (50 units per case)
ELD96LYLE	PALL Nanodyne™ ELD Filter - with female luer inlet, microbore tubing extension with "Y" injection site, clamp and male luer outlet (50 units per case)
ELD96LYLSE	PALL Nanodyne™ ELD Filter - with female luer inlet, standard bore extension tubing with "Y" injection site, clamp and male luer outlet (50 units per case)
ELD96NTE	PALL Nanodyne™ ELD Filter - with female luer inlet and male luer outlet with a rotating luer locking collar (40 units per case)
ELD96LL	PALL Posidyne® ELD Filter- with female luer inlet, microbore tubing extension with clamp and male luer outlet (48 units per case)
ELD96NT	PALL Posidyne® ELD Filter- with female luer inlet and male luer outlet with a rotating luer locking collar (40 units per case)
ELD96LYL	PALL Posidyne® ELD Filter- with female luer inlet, microbore tubing extension with "Y" injection site, clamp and male luer outlet (48 units per case)
ELD96LYLS	PALL Posidyne® ELD Filter- with female luer inlet, standard bore extension tubing with "Y" injection site, clamp and male luer outlet (48 units per case)
ELD96NYS	PALL Posidyne® ELD Filter- with standard bore extension tubing with "Y" injection site, clamp and male luer outlet (48 units per case)
ELD96NY	PALL Posidyne® ELD Filter- with microbore tubing extension with "Y" injection site, clamp and male luer outlet (48 units per case)
ELD96LLCJ	Pall Infusion Filter ELD - with female luer inlet, microbore tubing extension with removal clamp and male luer outlet (48 units per case)
100-0100	ELD96 device with 3mm tube port inlet and outlet non-sterile bulk packed.
100-0105	ELD96LLCE non-sterile bulk packed.
100-0108	ELD96NT non-sterile bulk packed.

Pall Corporation provides the information contained herein in good faith and states that it represents the best information currently available. However no warranties or representations are expressed or implied and Pall Corporation assumes no liabilities resulting from its use. Users should make their own investigations to determine the suitability of the information for their applications. In no way shall Pall Corporation be responsible for losses or damages resulting from the use or reliance on this information.